

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	LED driver
Name and address of the applicant	Philips Lighting B.V. High Tech Campus 45, 5656 AE Eindhoven The Netherlands
Name and address of the manufacturer	Philips Lighting B.V. High Tech Campus 45, 5656 AE Eindhoven The Netherlands
Name and address of the factory	☒ Additional information on page 2 Taiwan Surface Mounting Technology (SuZhou) Co., Ltd. No. 888 GanQuan Dong Road Economic Technology Development Zone WuJiang Suzhou China
Note: When more than one factory, please report on page 2	
Ratings and principal characteristics	CertaDrive 25W 0.6A 42V I 230V: Un: 220-240 V; fn: 50/60 Hz; In: 0,13 A; Pn: 28 W; PF: 0,9C; Uout: 30-42 V, 60 Vdc MAX; Iout: 0,6 A; Pout: 25 W; tc: 80 °C; Independent; SELV CertaDrive 30W 0.7A 42V I 230V: Un: 220-240 V; fn: 50/60 Hz; In: 0,15 A; Pn: 33 W; PF: 0,9C; Uout: 30-42 V, 60 Vdc MAX; Iout: 0,7 A; Pout: 30 W; tc: 80 °C; Independent; SELV CertaDrive 34W 0.8A 42V I 230V: Un: 220-240 V; fn: 50/60 Hz; In: 0,16 A; Pn: 37 W; PF: 0,9C; Uout: 30-42 V, 60 Vdc MAX; Iout: 0,8 A; Pout: 34 W; tc: 80 °C; Independent; SELV CertaDrive 38W 0.9A 42V I 230V: Un: 220-240 V; fn: 50/60 Hz; In: 0,19 A; Pn: 43 W; PF: 0,9C; Uout: 30-42 V, 60 Vdc MAX; Iout: 0,9 A; Pout: 38 W; tc: 80 °C; Independent; SELV CertaDrive 44W 1.05A 42V I 230V: Un: 220-240 V; fn: 50/60 Hz; In: 0,22 A; Pn: 49 W; PF: 0,9C; Uout: 30-42 V, 60 Vdc MAX; Iout: 1,05 A; Pout: 44 W; tc: 80 °C; Independent; SELV
Trademark (if any)	PHILIPS
Customer's Testing Facility (CTF) Stage used	CTF Stage 3

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051, NL-6825 MJ Arnhem, Netherlands



Date: 2018-12-18

Signature: Kreny Lin

page 1 of 3

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

Model / Type Ref.

CertaDrive 25W 0.6A 42V I 230V
CertaDrive 30W 0.7A 42V I 230V
CertaDrive 34W 0.8A 42V I 230V
CertaDrive 38W 0.9A 42V I 230V
CertaDrive 44W 1.05A 42V I 230V

Additional information (if necessary may also be reported on page 2)

☐ Additional information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60598-1:2014, IEC 61347-1:2015, IEC 61347-2-13:2014, IEC 61347-2-13:2014/AMD1:2016

National differences:

EU Group Differences

6045087.50

As shown in the Test Report Ref. No. which forms part of this Certificate

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051, NL-6825 MJ Arnhem, Netherlands



Date: 2018-12-18

Signature: Kreny Lin

 page 2 of 3

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

Additional factory

Hengdian Group Tospo Lighting Co., Ltd.

Hengdian Industrial Zone
322118 Dongyang City
Jinhua Zhejiang Province
China

Dongyang Tospo Lighting Optoelectronic Co., Ltd.

NO.5 NO.8 workshop, NO.88 Kexing Road, Hengdian Dongyang City,
Zhejiang Province
China

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051, NL-6825 MJ Arnhem, Netherlands



Date: 2018-12-18

Signature: Kreny Lin



page 3 of 3